

## PREBID QUERIES

Tender Ref.: Supply and Installation of Lab Furniture

Tender No. : NIPER/RBL/2021-22/13/21/13 Dated: 27.08.2021

A prebid meeting was held on 07/09/2021. The following bidders participated online.

1. Mr. PASHUPATI NATH GUPTA : **Reliable Scientific**
2. Mr. Jayanta, Mr. Parth Vyas and Mr. Rajesh Srivstava - **Citizen Industries**
3. Mr. Shubehendra Mishra, Mr. Abhijit – **LabGuard**
4. Mr. VISHAL Kumar - **Godrej**
5. Mr. Ranjit Singh: **Kewaunee**

In response to the queries received from prospective bidders, NIPER-R issues following clarifications and amendments.

Sr. No.	Query/ Clarification/ Deviation sought	Clarification/Response from NIPER - Raebareli
1.	Please clarify the scope of works for Electrical wiring as it is mentioned on Page No 26 of the tender documents under Electrical Trunking as "Wiring from connector to DB will be in client's scope". Please clarify the scope of wiring from DB to Lab Benches and Fume Hood.	The maximum distance of DB from the lab entrance is approximate 20 Ft. Wiring from DB box to lab benches and fume hood will be in the scope of vendor.
2.	Please confirm the scope of 3 phase electrical wiring from Blower to Fume Hood whether it will be under purchaser's scope or supplier's scope.	It falls under the supplier's scope.
3.	Please confirm the scope of works for Plumbing & Drainage, if any.	Plumbing and drainage inside the laboratory has to be covered by the supplier.
4.	The layout as provided in the tender documents is not clear. Hence, we request you to provide the layout in AutoCAD format for our internal working purpose.	The layout may be provided on request.
5.	Please confirm that any civil works like Blower Foundation, Wall Cut-out for duct line, Re-filling of cut-outs, etc. shall be under purchaser's scope	All kind of civil works are under the supplier's scope.

## PREBID QUERIES

**Tender Ref.: Supply and Installation of Lab Furniture**

**Tender No. : NIPER/RBL/2021-22/13/21/13 Dated: 27.08.2021**

6.	The applicable % of GST is no-where mentioned in the tender document. Please confirm whether any valid DSIR certificate is available with NIPER to avail the concession of GST@5% or we need to take full GST (i.e. GST@18%) into consideration.	NIPER-R has valid DSIR certificate. 5% GST is applicable accordingly.
7.	<b>Clarifications on the make list of items:</b>	<ul style="list-style-type: none"> <li>• <u>Steel</u> –TATA Steel/ JINDAL</li> <li>• <u>Powder Coating</u> - Kansai Nerolac/ Berger Paints/ Asian Paints</li> <li>• <u>Water Faucets</u> - Premier Polymer/Jaquar/Cera/Kohler</li> <li>• <u>Emergency Devices (Eye Wash / Safety Shower etc.) and Laboratory fittings</u> - Premier Polymer / Broen / Jaquar/Cera/Kohler</li> <li>• <u>Switches and Sockets, Data and LAN points</u> – Northwest/ Norisys/ Schneider/ Anchor/Havells</li> <li>• <u>Locks and Hinges</u> – Hettich/ Hafele/ Hindware/Godrej</li> <li>• <u>Drawer Slides and Rails</u> – Hettich/ Hafele/ Godrej</li> <li>• <u>Sink (PP Sink)</u> - Premier Polymer / Cera/Hindware</li> <li>• <u>Blower Motors</u> – Crompton/ Havells/ Kirloskar</li> <li>• <u>PP Centrifugal blower</u> - Premier Polymer</li> </ul>
8.	Request for site visit	Will be allowed on request.
9.	Compliances on SEFA and ASHRAE membership	Remain applicable as specified in the tender document.